

1. On Page 1 of your RFP, it references "Supply of the AMI-Enabled Electric and Water meters....." Are you a Water and Electric Utility?

**No. The RFP is for water only. The RFP has been corrected.**

2. Meter Boxes and Lids. – Do you have a specification of the lids you would require to replace broken lids in the field?

- a. Are your lids currently meter or polymer
- b.

**60% of lids are polymer, 40% are metal.**

- c. Most AMI providers will need Polymer lids OR drilled metal lids for our products to work the best with Polymer preferred. Can you take a couple of pictures of your lids with sizes.











3. What brand of meters do you have that you would like to be retrofitted?

The majority of meters are Neptune T-10's. Other brands found in the field are Sensus and Rockwell, those are very old models. Retrofitting may not be possible.

4. Do you have a storage facility on site for storing materials

Yes.

5. The RFP notes in your "Meter and Quantities" chart -  $\frac{3}{4}$ " meters.
  - a. Are these current meters  $5/8$ " x  $3/4$ ",  $3/4$ " x  $7-1/2$ " or  $3/4$ " x  $9$ "  
Meter sizes for  $3/4$  are  $5/8 \times 3/4$
  - b.  $4$ " meters – Are these compound or Turbine lay length  
 $2-4$ " Meters, both are Turbine.
  - c.  $2$ " meters – Are these  $2$ "  $10$ ",  $2$ " x  $15-1/4$ " or  $2$ " x  $17$ "  
 $30$   $2$ " meters, of which  $27$  are T-10  $2' \times 17"$ ,  $2$  are compound,  $1$  is turbine.